

Water Audit Level 1 Validation Document

Audit Information:

Utility: Santa Clarita Water Division PWS ID: 1910017
System Type: Potable Audit Period: Fiscal Year 2019/20
Utility Representation: Matt Dickens
Validation Date: 12/29/2020 Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 64 Data Validity Band (Level): Band III (51-70)
ILI: 2.17 Real Loss: 47.51 (gal/conn/day) Apparent Loss: 15.55 (gal/conn/day)
Non-revenue water as percent of cost of operating system: 5.2%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

Validator Information:

Water Audit Validator: Will Jernigan, P.E. Validator Qualifications: WAV Certified

Validator Provided